

ALUTECH SYSTEMS S.R.O TEST REPORT

SCOPE OF WORK

AAMA/WDMA/CSA 101/I.S.2/A440 TESTING ON A DUAL ACTION WINDOW

REPORT NUMBER

I2280.04-525-44 R0

TEST DATE(S)

05/25/18 , 06/01/18, 06/22/18

ISSUE DATE

10/25/23

RECORD RETENTION END DATE

06/22/24


PAGES

23

DOCUMENT CONTROL NUMBER

RT-R-AMER-Test-2804 (04/17/18)

© 2017 INTERTEK



TEST REPORT FOR ALUTECH SYSTEMS S.R.O

Report No.: I2280.04-525-44 R0

Date: 10/25/23

REPORT ISSUED TO

ALUTECH SYSTEMS S.R.O

Úherce 165 330 23

Úherce, Czech Republic

SECTION 1

SCOPE

This report is a reissue of report No. I2280.01-525-44-R2, dated 11/07/19. This report is rendered to Alutech Systems s.r.o through written authorization. Architectural Testing, Inc. (an Intertek company) dba Intertek Building & Construction (B&C) performed testing in accordance with AAMA/WDMA/CSA 101/I.S.2/A440 on their Dual Action Window. Results obtained are tested values and were secured by using the designated test method(s). Testing was conducted at the Intertek test facility in Farmingdale, NY. This report does not constitute certification of this product nor an opinion or endorsement by this laboratory.

SECTION 2

SUMMARY OF TEST RESULTS

TITLE	RESULTS
AAMA/WDMA/CSA 101/I.S.2/A440-17	AW-PG80-DAW
Design Pressure	±3830 Pa (±80.00 psf)
Air Infiltration	0.5 L/s/m ² (0.1 cfm/ft ²)
Water Penetration Resistance Test Pressure	720 Pa (15 psf)

For INTERTEK B&C:

COMPLETED BY:	Melissa Nuttall	REVIEWED BY:	Heather Stahl
TITLE:	Senior Project Manager	TITLE:	Regional Manager
SIGNATURE:		SIGNATURE:	
DATE:	10/25/23	DATE:	10/25/23

MMN;sar

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.