

ALUTECH SYSTEMS

IMPACT TEST

REPORT

SCOPE OF WORK

IMPACT (LEVEL D) TESTING ON FIXED WINDOW

REPORT NUMBER

M8463.03-550-18 R0

TEST DATE(S)

12/15/21 – 12/16/21

ISSUE DATE

07/11/22

LABORATORY CERTIFICATION NO.

14-0722.14

PAGES


11

DOCUMENT CONTROL NUMBER

ATI 00651 (08/21/17)

RT-R-AMER-Test-2816

© 2017 INTERTEK



TEST REPORT FOR ALUTECH SYSTEMS

Report No.: M8463.03-550-18 R0

Date: 07/11/22

REPORT ISSUED TO

ALUTECH SYSTEMS

s.r.o. Úherce 165 330 23
Úherce Česká republika

GLASS INC

510 Glen Iris Drive NE
Atlanta, GA 30308

SECTION 1

SCOPE

Intertek Building & Construction (B&C) was contracted by Alutech Systems to perform ASTM E1886, E1996, TAS 201 and TAS 203 testing in accordance with Florida Building Code for High Velocity Hurricane Zone requirements on their W72 Fixed window. Results obtained are tested values and were secured by using the designated test method(s). Testing was conducted at the Intertek B&C test facility in Lithia Springs, Georgia. This report does not constitute certification of this product nor an opinion or endorsement by this laboratory.

SECTION 2

SUMMARY OF TEST RESULTS

The specimen(s) tested met the performance requirements set forth in the protocols.

SPEC.	TEST PROTOCOL	DESIGN PRESSURE
1	ASTM E1886, E1996 & TAS 201, 203	+70 / -70 psf

For INTERTEK B&C:

COMPLETED BY: James Blakely
TITLE: Lab Manager
SIGNATURE:
DATE: 07/11/22

REVIEWED BY: Tanya Dolby, P.E.
TITLE: Senior Project Engineer
SIGNATURE:
DATE: 07/11/22

EC:jb

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.